



**Validity expires on 16.03.2025**

## ***Proceedings of the State Environment Impact Assessment Authority Kerala***

*Present: Prof. (Dr.) K.P. Joy, Chairman, Dr. J. Subhashini, Member &  
Sri. P.H.Kurian I.A.S Member Secretary.*

**Sub: SEIAA- Environmental Clearance for the proposed expansion of Hospital building at Jubilee Mission Medical College & Research Institute in Sy. Nos. 666/1, 666/2, 681, 669/1, 669/2, 669/3, 2245/2, 2245/3, 669/4, 669/4, 671/6, 671/1, 2247/1, 2247/6, 2245/4, at Chembukkavu Village and Trissur Taluk, Thrissur District, Kerala by Sri. Francis Pallikunnath - Granted-Orders issued**

### **State Environment Impact Assessment Authority, Kerala**

**No. 779/SEIAA/EC1/ 997/2015**

**dated, Thiruvananthapuram 17.03.2018**

- Ref: 1. Application received on 23.03.2015 from Fr. Francis Pallikkunnath, Director, Jubilee Mission Medical College & Research Institute, Bishop Alappat Road, Jubilee Mission P.O, Thrissur – 680005
2. Minutes of the 47<sup>th</sup> meeting of SEAC held on 13<sup>th</sup> & 14<sup>th</sup> October 2015.
3. Minutes of the 52<sup>nd</sup> meeting of SEAC held on 08<sup>th</sup> & 09<sup>th</sup> February 2016.
4. Minutes of the 51<sup>st</sup> meeting of SEIAA held on 29<sup>th</sup> March 2016.
5. Minutes of the 60<sup>th</sup> meeting of SEIAA held on 27<sup>th</sup> October 2017.
6. Minutes of the 66<sup>th</sup> meeting of SEIAA held on 07<sup>th</sup> April 2017.
7. Minutes of the 77<sup>th</sup> meeting of SEIAA held on 28<sup>th</sup> November 2017.
8. Minutes of the 83<sup>rd</sup> SEAC held on 20<sup>th</sup> & 21<sup>st</sup> December 2017.
9. Minutes of the 79<sup>th</sup> meeting of SEIAA held on 09<sup>th</sup> January 2018
10. Minutes of the 82<sup>nd</sup> meeting of SEIAA held on 15<sup>th</sup> March 2018.
11. Letter No.B1/62/2018/Env dt.14.03.2018 from Environment (B) Department.
12. Affidavit dated 19.03.2018 from Fr.Francis Pallikkunnath, Director, Jubilee Mission Medical College & Research Institute

### **ENVIRONMENTAL CLEARANCE NO.66/2018**

Fr.Francis Pallikunnath, Director, Jubilee Mission Medical College & Research Institute, Bishop Alappat Road, Jubilee Mission P.O, Thrissur – 680005, vide his application received on 23.03.2015 has sought Environmental Clearance under the EIA Notification, 2006 for the proposed expansion of hospital building in Sy. Nos. 666/1, 666/2, 681, 669/1, 669/2,

669/3, 2245/2, 2245/3, 669/4, 669/4, 671/6, 671/1, 2247/1, 2247/6, 2245/4, at Chembukkavu Village and Trissur Taluk, Thrissur District, Kerala. It is interalia, noted that the project comes under the Category B, 8(a) of Schedule of EIA Notification of MoEF.

**Details of the project as provided by the project proponent.**

**BASIC INFORMATION OF BUILDING PROJECT  
(To be filled in by the Project Proponent)  
PART A**

PROJECT DETAILS					
File No.	779/SEIAA/EC1/997/2015				
Name /Title of the project	Environmental Clearance for construction of hospital cum hostel building project in the existing hospital campus of M/s Jubilee Mission Medical College & Research Institute				
Name and address of project proponent.	Fr. Francis Pallikunnath, Director M/s Jubilee Mission Medical College & Research Institute, Bishop Alapat Road, Jubilee Mission P.O., Thrissur, Kerala-680005.				
Owner of the land	Private land and ownership of the land is with M Jubilee Mission Medical College & Research Institute.				
Survey Nos. District/Taluk/ and Village etc.	Sy. Nos. 666/1, 666/2, 681, 669/1, 669/2, 669/3, 2245/2, 2245/3, 669/4, 669/4, 671/6, 671/1, 2247/1, 2247/6, 2245/4, Chembukkavu Village, Thrissur Taluk, Thrissur District, Kerala.				
Category/Subcategory & Schedule	Category B 8(a)				
Date of submission of Application	23.03.2015				
Total Built up Area & No. of floors	Total Built up area 1,17,901.25 m <sup>2</sup> (Existing 96,758.687 m <sup>2</sup> ) Basement + Gr. Floor + 14 floors (Block-IV)				
No. of apartments	Not applicable. Construction of hospital building project				
Height of the building from the ground level	48.75 m.				
GPS Co-ordinate	<table border="1"> <tr> <td>Latitude (N)</td> <td>10°31'19.01" to 10°31'08.28"</td> </tr> <tr> <td>Longitude (E)</td> <td>76°13'51.29" to 76°13'33.06"</td> </tr> </table>	Latitude (N)	10°31'19.01" to 10°31'08.28"	Longitude (E)	76°13'51.29" to 76°13'33.06"
Latitude (N)	10°31'19.01" to 10°31'08.28"				
Longitude (E)	76°13'51.29" to 76°13'33.06"				
Brief description of the project.	Construction of 350 bed hospital project in plot area of about 10.18087 ha. The total built-up area of about 1,17,901.25sq.m.with supporting infrastructure facilities.				
Is it a new Project or expansion / modification of an existing project?	Environmental Clearance for construction of hospital cum hostel building (Block IV) project in the existing hospital campus.				
Details of the Project Cost	About Rs. 48 Crores				
If CRZ recommendation applicable?	Not applicable				
Distance from nearby habitation	The project site is in Chembukkavu Village and is				

	falling in Thrissur Corporation limits and several houses located within the 500 m. radius.
Distance from nearby forest, if applicable	None within the study area
Distance from protected area, Wildlife Sanctuary, National Park etc.	None within the study area
Distance from nearby streams/rivers/ National Highway Roads and Airport	Water body – <i>Thanikkudam</i> River- about 2 km. (N) Highway Road - N.H.-47 – abutting the site (N) Airport - Cochin Int. Airport, Nedumbassery - 50 Km. (SE)
Is ESA applicable? If so, distance from ESA limit	Not applicable
<b>IMPACT ON WATER</b>	
Details of water requirement per day in KLD	About 235 KL/day (which includes daily fresh water req. of about 186 KLD)
Water source/sources.	Source :- Stored Rain water (Tanks / Ponds), KWA water supply and treated water from STP.
Details of water requirements met from water harvesting.	The project has provision for rain water storage tanks / ponds which will be used as source of water during rainy days (concurrent use) & non-rainy days.
What are the impacts of the proposal on the ground water?	The project has provisions for well water as standby arrangement during non rainy days. The ground water abstraction will be of permissible limit of yield of the well. Therefore, no impact on the ground water.
<b>WASTE MANAGEMENT</b>	
Explain the facilities for Liquid waste Management	Provision of STP/ETP for treatment of sewage/effluent and it's fully recycling for meeting the water requirement for flushing, horticulture, boiler & make-up water req. for cooling towers attached to HVAC system within the site.
Solid Waste Management	Provision of bio-gas generation plant / bio-bin system within the project site for disposal of the bio-degradable solid waste.
E-Waste Management	<ul style="list-style-type: none"> <li>➤ Discarded computer parts, monitor, key boards etc. constitutes e-waste and this waste will be stored in an earmarked area.</li> <li>➤ e-waste will be generated after 4-5 years latency period</li> <li>➤ It will be stored in the service block building.</li> <li>➤ e-waste will be disposed as per e-Waste (Management &amp; Handling) Rules, 2016.</li> </ul>
Facilities for Sewage Treatment Plant	Yes. Provision of STP/ETP for treatment of sewage/effluent and it's fully recycling for meeting the water requirement for flushing, horticulture, boiler & cooling water requirement within the site.
How much of the water	The total domestic water requirement of about 235 KLD

requirement can be met from the recycling of treated waste water? (Facilities for liquid waste treatment)	(which includes daily fresh water requirement of about 186 KL). Treated water from STP to be used for flushing of toilets, horticulture, boiler & cooling requirement.
What is the incremental pollution load from waste water generated from the proposed activities?	Treated water from STP (with BOD level as per KSPCB norms) will be only after providing additional aeration in the final treated water storage tank.
How is the storm water from within the site managed?	Provision of roof rain water storage tanks & ponds for meeting the non-flushing water requirement. The excess roof rain water and the surface runoff of the site will be chenalized through garland drain. Intermediate rain water harvesting pits for ground water re-charge and excess runoff (if any) from the site will be chenalized to the drain (available along the external roads in south & west direction). The excess run-off will be discharged only after de-siltation & oil removal.
Will the deployment of construction labourers particularly in the peak period lead to unsanitary conditions around the project site ( Justify with proper explanation)	Yes. The proposed project has provision of labor colony and the domestic sewage will be channelised to the mobile STP for treatment of sewage during the construction period to handle the sewage. Also, it is proposed to have the food waste disposal from labor colony through the microbial bio-bin facility. Also, it is proposed to have a dedicated staff for good house keeping of the construction site premises and the labor colony premises. These measures will ensure a good hygienic conditions around the labor colony.
What on- site facilities are provided for the collection, treatment & safe disposal of sewage ? (Give details of the quantities of wastewater generation, treatment capacities with technology & facilities for recycling and disposal)	The project has provision of mobile STP for the treatment of sewage during construction phase and STP/ETP within the project premises to treat the sewage/effluent during operation phase. The technology for the treatment of the sewage is up to tertiary level. The total quantity of sewage generation will be 188 KL/day. The treated water will be fully recycled for meeting the flushing, horticulture & cooling water requirement.
Give details of dual plumbing system if treated waste is used for flushing of toilets or any other use.	The treated waste water from the proposed STP & ETP during the operation phase of the project will be used for flushing, horticulture, boiler & cooling purposes and for which dual plumbing system is proposed.
<b>TRAFFIC MANAGEMENT</b>	
Sufficiency of parking space (explain)	Yes. Sufficient parking space provided as per KMBR.
Width of access road	There are three approach roads to the project site, one is from 12 m. wide (Kuttanellur-Fatima Nagar Jn.) (south side), second one is from avg. width 22 m. wide (Fatima Nagar Jn. to East Fort Jn.) (west side) & third one is from private road connecting with N.H. 47 in the north side. These roads are well connected to entire city.
<b>ENERGY CONSERVATION</b>	
Details of power requirement and	The total power requirement is estimated to be about

source of supply, backup source etc. What is the energy consumption assumed per square foot of built-up area ? How have you tried to minimize energy consumption?	<p>600 kWh and will be from by Kerala State Electricity Board and Also, 1 MW energy through solar power. The project will make provision of D.G. Sets (1,500 kVA x 1 no. + 750 kVA x 1 nos.) as standby arrangement of electricity. The proposed project will have provision of power saving and maximum natural light will be provided to minimize energy consumption.</p> <p>Other measures are:</p> <ul style="list-style-type: none"> <li>➤ The project proponent in the campus intent to produce 1 MW of energy through solar power in the next 5 years. The first phase of this mission is already completed to produced 175 kW of non conventional energy. The work for production of 50 kW con-conventional energy is in progress.</li> <li>➤ Water cooled chillers in place of air cooled chillers which are energy intensive &amp; the treated water available from STP would be used as make-up water attached to the water cooled chillers.</li> <li>➤ Savings in energy by the use of LED lamps.</li> <li>➤ Thermal insulation by styro-foam in the roof to reduce heat gain to the building. Also, the side walls of the building will be constructed with hollow block for reduction in heat gain.</li> <li>➤ Building Management System ( BMS ) through sensors for maximizing the energy conservation.</li> <li>➤ Electrical fixtures &amp; HVAC unit would be of 5 star series as per Bureau of Energy Efficiency (BEE) to achieve reduction in energy consumption.</li> </ul>
What type of, and capacity of power back-up to you plan to provide?	The project proponent has made provision of D.G. Sets (1,500 kVA x 1 no. + 750 kVA x 1 nos.) as standby arrangement of electricity.
What are the characteristics of the glass you plan to use? Provide specifications of its characteristics related to both short wave and long wave radiation?	The glass used will be with low emissivity and the other specifications of the glass will comply with the norms as per ECBC.
What passive solar architectural features are being used in the building? Illustrate the applications made in the proposed project	All the relevant features are incorporated like the orientation of the building, shading effect etc.
Does the layout of streets & buildings maximize the potential for solar energy devices? Have you considered the use of street lighting, emergency lighting and solar hot water systems for use in the building complex ? Substantiate with details	Due consideration has been taken for maximum use of the solar energy while preparation of layout plan. The project proponent shall made provision for solar panel system (hot water purpose) in building block area and solar energy devices will be used for street lighting, emergency lighting in the proposed project.
Is the shading effectively used to	All the relevant features are incorporated like the

<p>reduce cooling/heating loads? What principles have been used to maximize the shading of Walls on the East and the West and the Roof? How much energy saving has been effected?</p>	<p>orientation of the building, shading effect etc.</p>
<p>Do the structure use energy-efficient space conditioning, lighting and mechanical systems? Provide technical details. Provide details of transformers and motor efficiencies, lighting intensity and air-conditioning load assumptions? Are you using CFC and HCFC free chillers? Provide specifications.</p>	<p>Suitable energy optimization adopted during the calculation of energy load of the proposed project. The space heating load will be minimized using passive solar structure and suitable buildings envelop material. Uses of incandescent lamp and halogen lamps have been avoided and energy efficient LED lamps will be used for all common area. The diesel generator sets shall be automatically controlled to optimize their usage based on the actual load requirements at any time. Variable frequency drive systems would be adopted for the lifts, etc to maximize the energy saving.</p>
<p>What are the likely effects of the building activity in altering the micro-climates? Provide a self assessment on the likely impacts of the proposed construction on creation of heat island &amp; inversion effects?</p>	<p>Open spaces are proposed within the site to creation of any heat islands. The roads and parking spaces would be with concrete slabs intermittent with grass on surrounding.</p>
<p>What are the thermal characteristics of the building envelope? (a) roof (b) external walls; and (c) fenestration? Give details of the materials used.</p>	<p>The building construction material namely bricks, concrete and steel are being used in the construction. U-factor, also known as Thermal Transmittance, is heat transmission in unit time through unit area of a material or construction and the boundary air films, induced by unit temperature difference between the environments on each side.</p> <p>The glass used with low emissivity and the other specifications of the glass will comply with the norms as per ECBC.</p>
<p>What is the rate of air non-conventional energy technologies are utilized in the overall energy consumption? Provide details of the renewable energy technologies used.</p>	<p>The use of non-conventional source of energy in the proposed construction project are as follows: -</p> <p>Solar Water Heater:-</p> <p>The proposed project would install solar panels for hot water requirements in the building block and hence the dependency on electricity for hot water generation can be minimized. This would conserve lot of coal which produces the electricity through public supply and also load on D.G. sets also would be reduced and there by conserve diesel.</p> <p>Solar Street Light: -</p> <p>It is also suggested to use solar cell powered street lights within the proposed project site for conservation of electricity.</p> <p>Use of LED Lamps: -</p> <p>The project proponent would use LED Lamp which</p>

	consume less electricity.
Details of renewable energy (non – conventional) used.	Solar water heating system for the hot water generation and solar power operated street lights.
<b>IMPACT ON AIR ENVIRONMENT</b>	
What are the mitigation measures on generation of dust, smoke , odours, fumes or hazardous gases	The dust generation during construction phase will be controlled by enclosures at appropriate locations and also by sprinkling of water for suppression of dust. The gas/smoke generation expected is from D.G. sets only and the gases will be vented out through stack of appropriate height.
Details of internal traffic management of the site.	The internal road width will be as per KMBR for the smooth vehicular movement. There are three approach roads to the project site, one is from 12 m. wide (Kuttanellur-Fatima Nagar Jn.) (south side), second one is from avg. width 22 m. wide (Fatima Nagar Jn. to East Fort In.) (west side) & third one is from private road connecting with N.H. 47 in the north side. These roads are well connected to entire city.
Details of noise from traffic, machines and vibrator and mitigation measures	The proposed project is a hospital building construction project and there would be some increase in noise and vibration due to the vehicular movement within the project site. The project has provision of large area for the parking for the vehicles and the parking arrangement which is planned, that there would be easy movement of vehicles within the project area and smooth movement is provided for the vehicles to reduce the traffic congestion.
Air quality monitoring in detail	The ambient air quality of the site carried out through an accredited laboratory which is well within the standard limit.
Will the proposal create shortage of parking space for vehicles? Furnish details of the present level of transport infrastructure and measures proposed for improvement including the traffic management at the entry & exit to the project site.	No shortage of parking space. Parking provisions would be made more than the KMBR requirements. The parking arrangement will be made within the site. There are total 9 entry / exits (5.5 m. to 8 m. wide) available within the campus.
Provide details of the movement patterns with internal roads, bicycles tracks, Pedestrian pathways, footpaths etc., with areas under each category	The conceptual plan clearly shows the internal traffic management with entry and exit to the proposed project site, all internal roads with width, pedestrian path ways etc. Further provision of ramps are proposed for the easy access to the building for physically challenged persons.
Will there be significant increase in traffic noise & vibrations? Give details of the sources and the measures proposed for mitigation of the above.	The proposed project is a construction of hospital building project and there would be some increase in noise and vibration due to the vehicular movement within the project site. The project has provision of large area for the parking for the vehicles and the parking arrangement which is planned, that there would be easy movement of vehicles within the project area and

	smooth movement is provided for the vehicles to reduce the traffic congestion.
What will be impact of DG sets & other equipments on noise levels & vibration in & ambient air quality around the project site? Provide details	The D.G. sets which would be used for the project will be with sound proof acoustic enclosures and hence there will be no impact to the surroundings. The D.G. sets would be attached with proper anti vibration pads to reduce any vibration impact to the site surrounding. The flue gases from the D.G. sets will be vented out through stack of appropriate height as per C.P.C.B. norms to reduce the impacts on air quality around the project site. The ambient noise level of the site is carried out through an accredited laboratory and the ambient noise level is well within the standard limit.
<b>IMPACT ON BIODIVERSITY AND ECO RESTORATION PROGRAMMES</b>	
Will the project involve extensive clearing or modification of vegetation (Provide details)	As part of the eco restoration, large number of saplings of native species would be planted. Due to the eco restoration, the impact to floral and faunal ecology will be short term.
What are the measures proposed to minimize the likely impact on vegetation (details of proposal for tree plantation/ landscaping)	As part of the eco restoration, large number of saplings of native species would be planted. Due to the eco restoration, the impact to floral and faunal ecology will be short term.
Is there any displacement of fauna – both terrestrial and aquatic. – If so what are the mitigation measures ? Presence of any endangered species or red listed category (in detail)	There will be no displacement of fauna due to the construction of the proposed project.  There is no presence of endangered species or red listed category.
<b>SOCIO- ECONOMIC ASPECTS</b>	
Will the proposal result in any change to the demographic structure of local population ? Provide the details.	The proposed project is a construction of hospital building. The proposed building, during operation phase on full occupancy of the project, the maximum population expected is about 3,150 persons (floating/fixed) and hence there will be influx of people (fixed) to the project area and surrounding. Some of the staff in the proposed hospital building may reside within the project vicinity and hence there will be increase in demographic structure.
Give details of the existing social infrastructure around the proposed project	There are several hospitals, schools, colleges, religious places, commercial and residential buildings, Govt. and private offices, which are located within the project vicinity. The vicinity map showing the surrounding details of the proposed project is provided.
Will the project cause adverse effects on local communities, disturbances to sacred sites or other cultural values? What are the safeguards proposed?	The proposed project is a construction of hospital building. The project would not cause any adverse effects on local communities, disturbance to sacred sites or other cultural values. The proposed project is hospital building and thereby the living index of the people around the project site will definitely improve. Also



	there will be various ancillary activities like convenient shops, transport facilities etc. attached to the project which will benefit the local people and change their living condition.
Out of the total plot area % of spaces provided for i)Recreational facility ii)Parking iii)Open Spaces	<ol style="list-style-type: none"> <li>1. Recreational facility – 31.54%</li> <li>2. Parking – 14.61% %</li> <li>3. Open Spaces – 31.34%</li> <li>4. Building area – 22.51% (coverage area)</li> </ol>
<b>BUILDING MATERIALS</b>	
May involve the use of building materials with high –embodied energy. Are the construction materials produced with energy efficient process? (Give details of energy conservation measures in the selection of building materials and their energy efficiency)	The hospital building will be of air conditioned building (except some portion), the selection of building materials plays a major role in the energy consumption. The proposed project will make all attempts to use to avoid building materials with high embodied energy. Cement blocks & hollow blocks will be replaced with country made red bricks. Further, the river sand will be replaced by manufactured sand from stone crushers. The glass used will be low emissivity and having U value as per ECBC norms.
Transport and handling of materials during construction may result in pollution, noise & public nuisance. What measures are taken to minimize the impacts?	<p>The proposed project is a construction of hospital building project. All measures are taken to minimize the impacts within the site &amp; surroundings.</p> <p>All vehicles which bring construction material to the site would possess Pollution Under Control Certificates (PUC). All vehicles would be of close body to avoid spread of dust from the loose materials, and vehicles which bring sand, stone dust, etc. would ensure that the above mentioned material are properly wetted during transportation to avoid dust generation. Pucca Road to be made in the construction site for the vehicle movement so that the dust generation due to the vehicular movement within the project site can be minimized. Stacking of construction material shall be confined to the project site only. All the D.G. Sets would have attached with Acoustic Enclosure for the sound pollution control and all sound generating construction activity to be minimized. Further barricading of the site with GI sheets of 10 ft height in the side abutting the public road during construction phase.</p>
Are recycled materials used in roads and structures? State the extent of savings achieved?	The plastic ( non-biodegradable solid waste ) will be used along with coal tar during the construction of internal roads. This will increase the life of roads.
Give details of the methods of collection, segregation & disposal of the garbage generated during the operation phases of the project.	<p><b>Solid waste</b></p> <ul style="list-style-type: none"> <li>➤ The Solid Waste Management Rules, 2016 will be followed in the Solid Waste Disposal Mechanism at the site during operation phase.</li> <li>➤ Collection &amp; segregation within the site (bio-degradable waste (green bins), non-biodegradable waste (blue bins) and domestic hazardous waste</li> </ul>

	<p>(yellow bins).</p> <ul style="list-style-type: none"> <li>➤ The recyclable waste like packaging material, paper etc. would be sold through vendors.</li> <li>➤ The Bio-degradable waste would be disposed through the bio-gas generation unit/bio bin system at site.</li> <li>➤ The bio-gas generated will be utilized in the kitchen/canteen area and the manure generated will be utilized for green area development within the premises.</li> </ul> <p>The domestic hazardous waste which includes discarded painted drums, pesticide cans, CFL bulbs, tube lights, expired medicines, broken mercury thermometers, used batteries, used needles and syringes and contaminated gauge etc. generated at the household level will be collected in yellow bins and to be handed over to authorized waste pickers or waste collectors.</p> <p><b><u>Bio-medical waste</u></b></p> <ul style="list-style-type: none"> <li>➤ Bio-medical waste like infectious beddings, cotton, swabs, used syringes, discarded medicines, etc. from the hospital would be generated. Bio-medical waste Management &amp; Handling Rules, 2016 will be followed.</li> <li>➤ Collection &amp; segregation at source by providing appropriate colour coded bins / containers as per the colour coding provided in the Bio-Medical Waste (Management &amp; Handling) Rules.</li> <li>➤ The bio-medical waste from the hospital outsourced through a Kerala State Pollution Control Board authorized agency (M/s Indian Medical Association Goes Eco Friendly, IMAGE).</li> </ul>
<p>Are there sufficient measures proposed for risk hazards in case of emergency such as accident at the site during construction &amp; post construction phase.</p>	<p><b>RISK MANAGEMENT</b></p> <p><i>Risk hazard from fire - List of equipments proposed for Fire Fighting Measures:-</i></p> <p>A. <i>The major equipments proposed for Fire Fighting Measures are Main Hydrant Pump, Sprinkler Pump, Diesel Engine Pump, Jockey Pump.</i></p> <p>B. <i>Capacity of Fire Water Storage Tanks &amp; Number:-</i>  <i>It is proposed to have Fire Water Storage Tank of appropriate capacity of overhead tank for fire fighting provided at the tower.</i></p> <p>C. <i>Fire Detecting Equipments: -</i>  <i>The Fire Detecting Equipments would be as per BIS and NBC norms.</i></p> <p>D. <i>Other Fire Fighting Measures: -</i>  <i>The other Fire Fighting Measures proposed includes, an Emergency Control Room, Separate Fire exit during emergency, all rooms with Fire Detector / Smoke Detector, Fire Extinguishers at each entry and exit point on each floor, (5 Kg, 10 Kg and 9 Ltr. capacity), Public</i></p>

	address system etc. The Fire Fighting Measures are backed by Electrical supply from D.G. sets in case of emergency. <i>The nearest fire station is at Thrissur Fire Station which is about 1 km. away from the project site.</i>
Storage of explosives/hazardous substance in detail	Yes, all precautionary measures in the storage & handling of HSD will be followed.
What precautions & safety measures are proposed against fire hazards? Furnish details of emergency plans	Details already provided above.
Litigation/court cases if any	No litigation/court case pending.
<b>AESTHETICS</b>	
Will the proposed constructions in any way result in the obstruction of a view, scenic amenity or landscapes? Are these considerations taken into account by the proponents?	No. There is no scenic beauty near the project site.
Will there be any adverse impacts from new constructions on the existing structures? What are considerations taken into account?	The project site is within the Corporation limit area. The surrounding area is residential / institutional developments. There are three side access roads to the project site which are well connected to entire city. There will be no any adverse impacts due to the development of the proposed project.
Whether there are any local considerations of urban form & urban design influencing the design criteria? They may be explicitly spelt out.	The proposed project would be constructed in conformity with the Kerala Municipal Building Rules (KMBR). As per seismic classification, the project site falls in Zone-III. No reported cloudburst in the area. Also, there is no hilly area around the project site, there is no chance of landslide. Structural design aspects as per the seismic codes – IS 1893 (2002), IS 13920 (1993) and IS 456 (2000) as applicable would be incorporated in our project.
Are there any anthropological or archaeological sites or artefacts nearby? State if any other significant features in the vicinity of the proposed site have been considered	There is no report of existence of any anthropological or archaeological site nearby the project area. The proposed project is located in Corporation limits of Thrissur. The vicinity map showing the site & surrounding area is provided.
Details of CSR activity and the amount set apart per year	The project proponent will continue the medical services in delivering their Corporate Social Responsibility in future too.
Details of NABET approved EIA Consultant engaged-Their name, address and accreditation details	M/s Environmental Engineers & Consultants Pvt. Ltd. (NABET Accredited Consultant Organization) Head Office :- A1-198, Janak Puri, New Delhi. Branch Office:- C-306, Kanchanjunga Apartments, Palarivattom P.O., Kochi, Kerala.
Details of Authorized Signatory and address for correspondence	Fr. Francis Pallikunnath, Director M/s Jubilee Mission Medical College & Research

	Institute, Bishop Alapat Road, Jubilee Mission P.O., Thrissur, Kerala-680005.
<b>SUMMARY AND CONCLUSION</b>	
Overall justification for implementation of the project.	Environment Clearance is required for Block-IV building.
Explanation of how adverse impact have been mitigated.	It is predicted that socio-economic impact due to this project will positively increase the chance of more employment opportunities for local inhabitants. There are no Resettlement and Rehabilitation issues involved in this project. The project infrastructures will be of use to people of the area. The revenue of the State Govt. will be definitely increase due to the proposed activity. The entire project area is devoid of any endemic / endangered flora and fauna. As part of the eco restoration with native species to a maximum possible extent. Also, rain water tanks / ponds are proposed for storage of rain water and for its subsequent use so as to conserve fresh water consumption. The municipal solid waste, bio-medical waste & e-waste will be handled and disposed as per norms. Thus the proposed project is not likely to affect the environment or adjacent ecosystem adversely and will ensure a sustainable development.

2. The proposal was considered in 47<sup>th</sup> meeting of SEAC held on 13<sup>th</sup> & 14<sup>th</sup> October 2015. The Committee decided to defer the proposal for field inspection and for submission of more realistic CSR. Accordingly the field inspection has been undertaken by the subcommittee on 19.12.2015. The details of the site inspection are extracted below:-

*This is a fully functional institute with many blocks dedicated to different activities of a Medical college. The expansion sought for is for one particular block ie Block 4 where area is to be increased from ~14000 sq.m to ~21000 sq.m. The work is in progress. The construction/expansion without EC can be viewed as violation though not in the strict sense. It is clarified that the permit for the construction was obtained earlier*

*Overall evaluation shows that the Institute has*

- 1. A number of buildings are seen in the campus giving a congested appearance. This is being overcome by demolition/conversion of existing structures into high rise buildings. The present expansion is part of such a strategy.*
- 2. Own source of water with few open wells, bore well and ponds as source. The overall requirement is totally met from own sources. Additional sources are available for further development. Water treatment plant is in place for the last 10 years.*
- 3. Sewage treatment plant is functional in the campus with a capacity to recycle 8 lakh lpd.*

4. *The biomedical waste is being treated insitu . The incinerator facility with two units has a capacity of 250 kg/hour. The height of the chimney is 57 m to prevent mixing of air at lower level. Shredding and autoclaving units are also functional.*
5. *Organic waste is used for generation of biogas. However, feeding of the waste to the biogas plant needs to be mechanised.*
6. *Separate entries are there and space has been provided for internal traffic and parking.*

*Considering these factors the EC to the institute may be recommended.*

3. The proposal was placed in the 52<sup>nd</sup> meeting of SEAC held on 08<sup>th</sup> & 09<sup>th</sup> February 2016. The Subcommittee observed that the construction work is almost over, and to that extent it is a case of violation. The Committee decided to Recommend to SEIAA for action against violation and issuance of EC on completion of above proceedings stipulating over and above the general conditions a specific condition to mechanize the feeding to the biogas plant. The proponent should also submit more realistic CSR to SEIAA.

4. The proposal was considered by SEIAA in its 51<sup>st</sup> meeting held on 29<sup>th</sup> March 2016. The Authority decided to initiate violation proceedings. Pursuantly, SEIAA issued show cause notice to the proponent vide letter No. 779/SEIAA/EC1/997/2015 dated 01-06-2016. The proponent requested vide letter No nil dated 12-08-2016, to grant two more weeks to prepare a detailed reply to the show cause notice. Thereon the proponent submitted the detailed explanation before SEIAA on 19-10-2016, and requested to accept their explanation, because they have stopped all the work on the building awaiting EC. The proponent also submitted an Affidavit undertaking that they 'shall not carry out any work on the building until the EC is issued for the new block'.

5. The proposal was placed in the 60<sup>th</sup> meeting of SEIAA held on 27<sup>th</sup> October 2016. Violation is initiated only in respect of hospital building which requires E.C. There is the O.M. No. S.O. 3252 (E) dated 22.12.2014 of the MoEF specifically requiring prior E.C for the hospital building attached to Medical College projects. The project for which E.C is being considered by SEIAA is not exceptional for the purview of EIA notification. SEAC has not only not recommended the hospital project for E.C but has recommended to initiate violation proceedings based on which is the show cause notice issued. The explanations furnished by the proponent are irrelevant. The Authority noted that the action proposed in the show cause

notice dated 01-06-2016 is to be confirmed and decided to initiate credible action against violation. Hence Stop Memo was issued on 16.01.2017.

The proponent submitted a revised application for obtaining environmental clearance for their Hospital Complex and have requested that they may be given an opportunity for submission of a revised application which will clarify the status of built-up area of all buildings (existing & proposed) within their campus.

6. The proposal was placed in the 66<sup>th</sup> SEIAA meeting held on 07<sup>th</sup> April 2017. The Authority decided to inform the proponent to submit revised form 1, Form 1A, conceptual plan and other documents regarding the actual status of construction.

The proponent submitted the revised Form I, Form I A Conceptual Plan and other related documents on 22.11.2017. The proponent stated that the hospital component consist of basement, ground floor and eight upper floors with a total built up area of 14,377 sqmtrs and a height of 29.85 m. The building already has a building permit (DW3/PW 7/BA/239/06-07 dt.05.01.2008) from Thrissur Corporation. Since the built up area of the project is less than 20,000 m the hospital building it does not require Environmental Clearance.

In the proposal the additional six floors above the hospital building (Block IV) is for the Post Graduate Medical Student's Hostel consisting of 9 to 14 floors with a total built up area of 8, 254.86 m and the hostel component is exempted from Environmental Clearance as per EIA notification dt.22.12.2014 of MoEF (amendment of EIA Notification No.S.O3252 . So they requested to delist their proposal.

7. The proposal was placed in the 77<sup>th</sup> meeting of SEIAA held on 28<sup>th</sup> November 2017. In the light of the representation stating that the hospital component of the building is below 20,000 m<sup>2</sup> (ie. only 14,377 m<sup>2</sup>) Authority decided to return the proposal to SEAC for reconsideration whether violation proceedings recommended by the Committee should be dropped.

8. The proposal was considered in the 83<sup>rd</sup> SEAC held on 20<sup>th</sup> & 21<sup>st</sup> December 2017. The Committee perused all the records submitted with the proposal along with the 2006 EIA Notification and various other OMs issued by MOEF & CC in this regard. The Committee observed that as per Para 2 (ii) of the EIA Notification 2006, which explicitly says that expansion and modernization of existing projects or activities listed in the Schedule to this

notification with addition of capacity beyond the limits specified for the concerned sector, that is, projects or activities which cross the threshold limits given in the Schedule, after expansion or modernization; will require prior EC.

In the light of the above facts, the existing built up area has to be reckoned while deciding applicability of the above Notification for each project. In this case, even after reducing the built up area for Medical College & Hostels, it crosses the threshold limit of 20,000 m<sup>2</sup>. Hence, the violation already reported by the Committee still stands. The Committee also observed that the violation proceedings against the project proponent has followed all necessary channels, namely stoppage of work, intimation to the District Collector and submission of a resolution by the governing body. Hence violation proceedings against the proponent can be deemed to have been initiated and Environmental Clearance already recommended by the Committee can be issued.

9. The proposal was placed in the 79<sup>th</sup> meeting of SEIAA held on 09<sup>th</sup> January 2018. Authority decided to get a legal opinion from Government as to whether the violators can only be delisted as per the provisions of Environment Protection Act 1986 or whether EC can be given as violation proceedings against the proponent have already been initiated as recommended by SEAC. The legal opinion may be made applicable to other violation cases also based on the merit of each case.

Letter no. 779/EC1/997/SEIAA/2015 dated 15.02.2018 was send to Government seeking legal opinion and reply was received on 13.03.2018 vide reference 11<sup>th</sup> cited.

10. The proposal was finally placed in the 82<sup>nd</sup> meeting of SEIAA held on 15<sup>th</sup> March 2018. Meanwhile S.O No.1030 (E) dt.08<sup>th</sup> March 2018 has been issued by MoEF for dealing with violation cases. The said Notification has delegated the powers to SEIAA for dealing with violation cases. SEAC has recommended the proposal for issuance of EC, considering the case only as a technical violation.

Hence Authority accepted the recommendation of SEAC in the light of the above Notification and legal opinion and decided to issue EC subject to general conditions in addition to the specific condition as suggested by SEAC. The proponent should provide free medical treatment to BPL patients suffering from serious ailments referred to them by the local body to an amount equivalent to 2% of the total project cost. A notarised affidavit for the commitment of CSR activities and also agreeing all the above specific and general

conditions should be submitted before the issuance of EC. The proponent has submitted the affidavit vide reference 12<sup>th</sup> cited.

11. Environmental Clearance as per the EIA Notification 2006 is therefore granted for the proposed expansion of Hospital building at Jubilee Mission Medical College & Research Institute in Sy. Nos. 666/1, 666/2, 681, 669/1, 669/2, 669/3, 2245/2, 2245/3, 669/4, 669/4, 671/6, 671/1, 2247/1, 2247/6, 2245/4, at Chembukkavu Village and Trissur Taluk, Thrissur District, Kerala by Fr. Francis Pallikunnath, Director, Jubilee Mission Medical College & Research Institute, Bishop Alappat Road, Jubilee Mission P.O, Thrissur – 680005, subject to the conditions in para 3 & 10 above and the usual general conditions for projects other than mining appended hereto and the following green conditions should be strictly adhered to.

**Green Conditions.**

1. *Adequate rain water harvesting facilities shall be arranged for.*
2. *Technology and capacity of the STP to be indicated with discharge point (if any) of the treated effluent.*
3. *Effluent water not conforming to specifications shall not be let out to water bodies.*
4. *Maximum reuse of grey water for toilet flushing and gardening and construction work shall be ensured.*
5. *Dual plumbing for flushing shall be done.*
6. *Provisions for disposal of e-wastes, solid wastes, non-biodegradables and separate parking facility for the buildings shall be provided.*
7. *Generation of solar energy to be mandatory for own use and/or to be provided to the grid.*
8. *There shall be no compromise on safety conditions and facilities to be provided by the project proponent, which shall be ensured for occupation, regularisation or consent to operate.*

12. The Clearance will also be subject to full and effective implementation of all the undertakings given in the application form, all the environmental impact mitigation and management measures undertaken by the project proponent in the documents submitted to SEIAA, and the mitigation measures and waste management proposal as assured in the Form - 1 and Form-1A, Environment Management Plan as submitted. The assurances and clarifications given by the proponent in the application and related documents will be deemed



to be part of these proceedings as conditions as undertaken by the proponent, as if incorporated herein.

13. Validity of the Environmental Clearance will be seven years from the date of issuance of E.C, subject to inspection by SEIAA on annual basis and compliance of the conditions, subject to earlier review of E.C in case of violation or non-compliance of any of the conditions stipulated herein or genuine complaints from residents within the scrutiny area of the project.

14. Compliance of the conditions herein will be monitored by the State Environment Impact Assessment Authority or its agencies and also by the Regional Office of the Ministry of Environment and Forests, Govt. of India, Bangalore.

- i. Necessary assistance for entry and inspection by the concerned officials and staff should be provided by the project proponents.
- ii. Instances of violation if any shall be reported to the District Collector, Thrissur to take legal action under the Environment (Protection) Act 1986.
- iii. The given address for correspondence with the authorized signatory of the project is, Fr.Francis Pallikunnath, Director, Jubilee Mission Medical College & Research Institute, Bishop Alappat Road, Jubilee Mission P.O, Thrissur – 680005.

Sd/-

**P.H.KURIAN I.A.S**  
**Member Secretary (SEIAA)**

To,


Fr.Francis Pallikunnath,  
Director,  
Jubilee Mission Medical College & Research Institute,  
Bishop Alappat Road,  
Jubilee Mission P.O,  
Thrissur – 680005

Copy to:

1. MoEF Regional Office, Southern Zone, Kendriya Sadan, 4<sup>th</sup> Floor, E&F Wing, II Block, Koramangala, Bangalore-560034
2. The Additional Chief Secretary to Government, Environment Department
3. The District Collector, Thrissur
4. The District Town Planner, Thrissur
5. The Tahsildar, Thrissur Taluk, Thrissur District

6. The Member Secretary, Kerala State Pollution Control Board  
7. The Secretary, Corporation of Thrissur, M.O Road, Thrissur 680 005  
8. Chairman, SEIAA, Kerala  
9. Website  
10. Stock file  
11. O/c

Forwarded/By order

  
Administrator, SEIAA



SEIAA

**GENERAL CONDITIONS** *(for projects other than mining)*

- (i) Rain Water Harvesting capacity should be installed as per the prevailing provisions of KMBR / KPBR, unless otherwise specified elsewhere.
- (ii) Environment Monitoring Cell as agreed under the affidavit filed by the proponent should be formed and made functional.
- (iii) Suitable avenue trees should be planted along either side of the tarred road and open parking areas, if any, inclusive of approach road and internal roads.
- (iv) The project shall incorporate devices for solar energy generation and utilization to the maximum possible extent with the possibility of contributing the same to the national grid in future.
- (v) Safety measures should be implemented as per the Fire and Safety Regulations.
- (vi) STP should be installed and made functional as per KSPCB guidelines including that for solid waste management.
- (vii) The conditions specified in the Companies Act, 2013 should be observed for Corporate Social Responsibility.
- (viii) The proponent should plant trees at least 5 times of the loss that has been occurred while clearing the land for the project.
- (ix) Consent from Kerala State Pollution Control Board under Water and Air Act(s) should be obtained before initiating activity.
- (x) All other statutory clearances should be obtained, as applicable, by project proponents from the respective competent authorities including that for blasting and storage of explosives.
- (xi) In the case of any change(s) in the scope of the project, the project would require a fresh appraisal by this Authority.
- (xii) The Authority reserves the right to add additional safeguard measures subsequently, if found necessary, and to take action including revoking of the environment clearance under the provisions of the Environment (Protection) Act, 1986, to ensure effective implementation of the suggested safeguard measures in a time bound and satisfactory manner.
- (xiii) The stipulations by Statutory Authorities under different Acts and Notifications should be complied with, including the provisions of Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and control of Pollution) act 1981, the Environment (Protection) Act, 1986, the Public Liability (Insurance) Act, 1991 and EIA Notification, 2006.
- (xiv) The environmental safeguards contained in the EIA Report should be implemented in letter and spirit.
- (xv) Provision should be made for supply of kerosene or cooking gas and pressure cooker to the labourers during construction phase.
- (xvi) Officials from the Regional of MOEF, Bangalore who would be monitoring the implementation of environmental safeguards should be given full co-operation, facilities and documents/data by the project proponents during their inspection. A complete set of all the documents submitted to MoEF should be forwarded to the CCF, Regional Office of MOEF, Bangalore.
- (xvii) These stipulations would be enforces among others under the provisions of Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control Pollution) at 1981, the Environment (Protection) Act, 1986, the Public Liability (Insurance) Act, 1991 and EIA Notification, 2006.

- (xviii) Environmental Clearance is subject to final order of the Hon'ble Supreme Court of India in the matter of Goa Foundation Vs. Union of India in Writ Petition (Civil) No.460 of 2004 as may be applicable to this project.
- (xix) Any appeal against this Environmental Clearance shall lie with the National Environment Appellate Authority, if preferred, within a period of 30 days as prescribed under section 11 of the National Environment Appellate Act, 1997.
- (xx) The project proponent should advertise in at least two local newspapers widely circulated in the region, one of which (both the advertisement and the newspaper) shall be in the vernacular language informing that the project has been accorded Environmental Clearance and copies of clearance letters are available with the Department of Environment and Climate Change, Govt. of Kerala and may also be seen on the website of the Authority at [www.seiaakerala.org](http://www.seiaakerala.org). The advertisement should be made within 10 days from the date of receipt of the Clearance letter and a copy of the same signed in all pages should be forwarded to the office of this Authority as confirmation.
- (xxi) A copy of the clearance letter shall be sent by the proponent to concerned GramaPanchayat/ District Panchayat/ Municipality/Corporation/Urban Local Body and also to the Local NGO, if any, from whom suggestions / representations, if any, were received while processing the proposal. The Environmental Clearance shall also be put on the website of the company by the proponent.
- (xxii) The proponent shall submit half yearly reports on the status of compliance of the stipulated EC conditions including results of monitored data **(both in hard copies as well as by e-mail)** and upload the status of compliance of the stipulated EC conditions, including results of monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the respective Regional Office of MoEF, Govt. of India and also to the Directorate of Environment and Climate Change, Govt. of Kerala.
- (xxiii) The details of Environmental Clearance should be prominently displayed in a metallic board of 3 ft x 3 ft with green background and yellow letters of Times New Roman font of size of not less than 40.
- (xxiv) The proponent should provide notarized affidavit (*indicating the number and date of Environmental Clearance proceedings*) that all the conditions stipulated in the EC shall be scrupulously followed.

## **SPECIFIC CONDITIONS**

### **I. Construction Phase**

- i. "Consent for Establishment" shall be obtained from Kerala State Pollution Control Board under Air and Water Act and a copy shall be submitted to the Ministry before start of any construction work at the site.
- ii. All required sanitary and hygienic measures should be in place before starting construction activities and to be maintained throughout the construction phase.
- iii. A First Aid Room will be provided in the project both during construction and operation of the project.
- iv. Adequate drinking water and sanitary facilities should be provided for construction workers at the site, Provision should be made for mobile toilets. The safe disposal of wastewater and solid wastes generated during the construction phase should be ensured.
- v. All the topsoil excavated during construction activities should be stored for use in horticulture/landscape development within the project site.

- vi. Disposal of muck during construction phase should not create any adverse effect on the neighbouring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in approved sites with the approval of competent authority.
- vii. Soil and ground water samples will be tested to ascertain that there is no threat to ground water quality by leaching of heavy metals and other toxic contaminants.
- viii. Construction spoils, including bituminous material and other hazardous materials, must not be allowed to contaminate watercourses and the dump sites for such material must be secured so that they should not leach into the ground water.
- ix. Any hazardous waste generated during construction phase, should be disposed off as per applicable rules and norms with necessary approval of the Kerala State Pollution Control Board.
- x. The diesel generator sets to be during construction phase should be low sulphur diesel type and should conform to Environment (Protection) Rules prescribed for air and noise emission standards.
- xi. The diesel required for operating DG sets shall be stored in underground tanks and if required, clearance from Chief Controller of Explosives shall be taken.
- xii. Vehicles hired for bringing construction material to the site should be in good condition and should have a pollution check certificate and should conform to the applicable air and noise emission standards and should be operated only during non-peak hours.
- xiii. Ambient noise levels should conform to residential standards both during day and night. Incremental pollution loads on the ambient air and noise quality should be closely monitored during construction phase. Adequate measures should be made to reduce ambient air and noise level during construction phase, so as to conform to the stipulated standards by CPCB/KSPCB.
- xiv. Fly ash should be used as building material in construction as per the provisions of Fly Ash Notification of September, 1999 and amended as on 27<sup>th</sup> August 2003. (The above condition is applicable Power Stations).
- xv. Ready mixed concrete must be used in building construction.
- xvi. Storm water control and its re-use per CGWB and BIS standards for various applications.
- xvii. Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices referred.
- xviii. Permission to draw ground shall be obtained from the Computer Authority prior to construction/operation of the project.
- xix. Separation of grey and black water should be done by the use of dual plumbing line for separation of grey and black water.
- xx. Fixtures for showers, toilet flushing and drinking should be of low flow either by use of aerators or pressure reducing devices or sensor based control.
- xxi. Use of glass may be reduced by upto 40% to reduce the electricity consumption and load on airconditioning. If necessary, use high quality double glass with special reflective coating in windows.
- xxii. Roof should meet prespective requirement as per Energy Conservation Building Code by using appropriate thermal insulation material to fulfil requirement.
- xxiii. Opaque wall should meet perspective requirement as per energy Conservation Building Code which is proposed to be mandatory for all airconditioned spaces while it is aspirational for non-airconditioned spaces by use of appropriate thermal insulation material to fulfil requirement.

- xxiv. The approval of the competent authority shall be obtained for structural safety of the buildings due to earthquake, adequacy of fire fighting equipments, etc. as per National, Building Code including protection measures from lightening etc.
- xxv. Regular supervision of the above and other measures for monitoring should be in place all through the construction phase, so as to avoid disturbance to the surroundings.
- xxvi. Under the provisions of Environment (Protection) Act, 1986, legal action shall be initiated against the protect proponent if it was found that construction of the project has been started without obtaining environmental clearance.

## **II. Operation Phase**


- i. The installation of the Sewage Treatment Plant (STP) should be certified by an independent expert and a report in this regard should be submitted to the Ministry before the project is commissioned for operation. Treated affluent emanating from STP shall be recycled / reused to the maximum extent possible. Treatment of 100% grey water by decentralised treatment should be done. Discharge of unused treated affluent shall conform to the norms and standards of the Kerala State Pollution Control Board. Necessary measures should be made to mitigate the odour problem from STP.
- ii. The solid waste generated should be properly collected and segregated. Wet garbage should be composted and dry/inert solid waste should be disposed off to the approved sites for land filling after recovering recyclable material.
- iii. Diesel power generating sets proposed as source of back up power for elevators and common area illumination during operation phase should be of enclosed type and conform to rules made under the Environment (Protection) Act, 1986. The height of stack of DG sets should be equal to the height needed for the combined capacity of all proposed DG sets. Use low sulphur diesel. The location of the DG sets may be decided with in consultation with Kerala State pollution Control Board.
- iv. Noise should be controlled to ensure that it does not exceed the prescribed standards. During night time the noise levels measured at the boundary of the building shall be restricted to the permissible levels to comply with the prevalent regulations.
- v. The green belt of the adequate width and density preferably with local species along the periphery of the plot shall be raised so as to provide protection against particulates and noise.
- vi. Weep holes in the compound walls shall be provided to ensure natural drainage of rain water in the catchment area during the monsoon period.
- vii. Rain water harvesting for roof run-off and surface run-off, as plan submitted should be implemented. Before recharging the surface run off, pre-treatment must be done to remove suspended matter, oil and grease. The borewell for rainwater recharging should be kept at least 5 mts. above the highest ground water table.
- viii. The ground water level and its quality should be monitored regularly in consultation with Central Ground Water Authority.
- ix. Traffic congestion near the entry and exit points from the roads adjoining the purposed project site must be avoided. Parking should be fully internalized and no public space should be utilized.
- x. A Report on the energy conservation measures confirming to energy conservation norms finalise by Bureau of Energy Efficiency should be prepared incorporating details about building materials & technology, R & U Factors etc and submit to the Ministry in three months time.

- xi. Energy conservation measures like installation of CFLs/TFLs for the lighting the areas outside the building should be integral part of the project design and should be in place before project commissioning. Use CFLs and TFLs should be properly collected and disposed off/sent for recycling as per the prevailing guidelines/rules of the regulatory authority to avoid mercury contamination. Use of solar panels may be done to the extent possible.
- xii. Adequate measures should be taken to prevent odour problem from solid waste processing plant and STP.
- xiii. The building should have adequate distance between them to allow movement of fresh air and passage of natural light, air and ventilation.

### **III Post Operational Phase**

Environmental Monitoring Committee with defined functions and responsibility should foresee post operational environmental problems e.g. development of slums near the site, increase in traffic congestion, power failure, increase in noise level, natural calamities, and increase in suspended particulate matter etc. solve the problem immediately with mitigation measures



  
For Member Secretary, SEIAA

